

WEEE Number: 80133970

INSTRUCTION MANUAL

ESS SERIES BATTERY PACK



MODEL	SKU
VT-48200B	11523



INTRODUCTION

Thank you for selecting and buying V-TAC Product. V-TAC will serve you the best. Please read these instructions carefully & keep this user manual handy for future reference. If you have any another query, please contact our dealer or local vendor from whom you have purchased the product. They are trained and ready to serve you at the best.



MULTI-LANGUAGE MANUAL QR CODE

Please scan the QR code to access the manual in multiple languages.



Points de collecte sur www.quefairedemesdechets.fr





CONTENTS

1 Foreword	1
2 Safety	2
2.1 Safety Precautions	2
2.2 Abuse Operation	2
3 Overview	
3.1 Product Description	3
3.1.1 Features	
3.1.2 Basic Functions	3
3.2 Application Scenario	. 4
4 Application Description	. 5
4.1 Parallel Connection Application	
4.2 Low-temperature Application	5
4.3 Low battery-capacity Storage (SOC≤5%)	5
4.4 Application of Nearing the Ocean	6
5 Product Introduction	. 7
5.1 Panel Introduction	7
5.1.1 Panel Function	
5.1.2 Indicator Description	8
5.1.3 DIP Address	10
5.1.4 Communication Port Definition	11
5.1.5 Dry Contact Alarm Definition	11
6 Installation	12
6.1 Tools Preparation	
6.2 Unpacking and Inspection	
6.3 Preparing for Installation	
6.4 Installation	. 13
6.5 Cable Connection	
7 Power On	18
7.1 Power-on Operation	18
7.1.1 Pre-check Preparing Power-on Operation	
7.1.2 Power on	
7.1.3 UIWare Configuration	
7.1.4 Check by UI software	
7.2 Power System Parameter Setting	
8 Shipment & Maintenance & Storage	. 22
8.1 Shipment	
8.2 Maintenance	
8.2.1 Battery Maintenance Considerations	
8.2.2 Routine Maintenance	
8.3 Battery Storage	
9 Trouble Shooting	
10 Warranty	
11 Abbreviations	. 28



Overview

This user manual mainly introduces the 48V 200Ah series product introduction, application description, installation instructions, power-on instructions, maintenance instructions and provides instructions for technical support engineers, maintenance engineers and users.

Reader

This document is mainly applicable to the following engineers

- Technical Support Engineer
- Installation Personnel
- Maintenance Engineer

Signs

The following signs may appear in this article, and their meanings are as follows.

Sign	Meaning	Description
▲ DANGER	Danger	Indicates a hazard with a high level of risk that will cause death or serious injury if not avoided.
▲ WARNING	Warning	Indicates a hazard with a moderate risk that may cause death or serious injury if not avoided.
ATTENTION	Notice	Indicates a hazard with a low level of risk that may cause minor or moderate harm if not avoided.
NOTE	Explanation	Supplementary explanation of key information in the main text. "Explanation" is not safety warning information, and does not involve personal, equipment and environmental damage information.



This marking indicates that this product should not be disposed of with other household wastes.



Caution, risk of electric shock.



2.1 Safety Precautions

Before carrying out battery work, you must read carefully the safety precautions and master the correct installation and connection methods of the battery.

- Prohibit to turn it upside down, tilt, or collide.
- Prohibit to short-circuit the positive and negative poles of the battery, otherwise it will cause the battery to be damaged.
 - Prohibit to throw the battery pack into a fire source.
- Prohibit to modify the battery, and it is strictly prohibited to immerse the battery in water or other liquids.
 - DO NOT place installation tools on the battery during battery installation.
- DO NOT disassemble, squeeze, bend, deform, puncture, or shred the battery without the authorization of Vtac and authorized dealers.
- DO NOT exceed the temperature range, otherwise it will affect the battery performance and safety.
- The battery circuit must be kept disconnecting status during installation and maintenance operations.
- Check the battery connection end bolts regularly to confirm that the bolts are tight.

2.2 Abuse Operation

The battery pack needs to avoid abuse operations under the following (including but not limited to) conditions:

Abuse Operation	Protection Description
Reverse connection of positive and negative poles	If the positive and negative poles are connected reversely, the battery will be directly damaged.
External short circuit	If the battery pack is short circuited externally, the battery will be directly damaged.
Series connection application	The battery pack does not support the application of battery packs in series. If the battery packs are forcedto be connected in series, the batteries may be directly damaged, and may even cause fire, explosion and other dangers.



3.1 Product Description

The 48V 200Ah series products use lithium iron phosphate (LFP) as the positive electrode material. It can be widely used in telecom scenario and energy storage systems such as off-grid, grid-connected, and home use.

The battery pack is composed of 15 cells/16 cells of LFP batteries in series connection, with low self-discharge, high energy density, and no memory effect. This type of battery also has excellent performance in high rate, long cycle life, wide temperature range, and high safety.

3.1.1 Features

High energy density

Higher volume ratio energy and weight ratio energy.

Maintenance-free

The battery pack is maintenance-free in the process of using, which can save customers' battery operation, maintenance testing costs and reduce the frequency of on-site replacement.

• Long cycle life

The battery pack life is 3 times long than the ordinary lead-acid batteries.

• Excellent temperature characteristics

When charging, the battery working temperature can reach $0^{\circ}\text{C} \sim +60^{\circ}\text{C}$ (recommended using temperature: +15 \sim +35°C). When discharging, the battery working temperature can reach -20°C \sim +60°C(recommended using temperature: +15 \sim +35°C).

3.1.2 Basic Functions

Monitor

The battery system uses a high-performance BMS, it has protection functions such as current, voltage.

Alarm

Support abnormal alarms such as over-voltage, under-voltage, over-current, high and low temperature, battery failure, hardware failure, etc.

Communication

Provide dual RS485 interfaces, upload alarming and status data through the RS485/CAN communication protocol.



• Parallel connection application

Support multiple battery packs in parallel, RS485/CAN communication supports up to 6 groups without control unit (or max supports 15 groups with control unit) .

Balance function

Support the cells balance function.

• Extended function

Extended SNMP V2, SNMP V3, LCD, anti-theft, etc.

▶ 3.2 Application Scenario

The battery pack is used to provide backup power to the power system, and can be used for telecom, household energy storage, solar energy storage and other application scenarios.

The normal working operation diagram of the battery pack can be as shown in the figure below.





Figure 3-1 Normal Working Operation Diagram of the Battery Pack



▶ 4.1 Parallel Connection Application



The battery packs support parallel connection, and synchronously increases the backup time or backup power.

Multiple battery packs of parallel connection need to use RS485/CAN to communicate, pay attention to the DIP switch settings. Turn off the batteries before connecting them in parallel.

▶ 4.2 Low-temperature Application

Low-temperature Charging

The battery pack does not support direct charging of the battery below 0°C. When the minimum temperature of the battery is below 0°C, the BMS will cut-off the charging circuit and cannot be charged.

Low-temperature Discharging

The battery pack does not support discharge below -20°C. When the minimum temperature of battery is below -20°C, the BMS will cut-off the discharge circuit and cannot discharge.

▶ 4.3 Low battery-capacity Storage (SOC≤5%)

After the battery pack is power off, there will be BMS static power consumption and self-discharge loss. In actual scenarios, it is necessary to avoid low-battery-power state (SOC≤5%) storage. If it is unavoidable, the longest storage period is 30

4 Application Description



days@25°C, 15 days@45°C. The battery needs to be recharged in time after storage, otherwise the battery may be damaged due to over-discharge, and the entire battery pack needs to be replaced.

The following conditions may cause the battery pack to be stored in a discharged state:

- After the utility power failure, the line/fault cannot be eliminated in time, and the power supply cannot be restored for a long time.
- After the installation and commissioning work is completed, the utility power is turned off directly, but the battery pack is not powered off, which will cause the battery to enter the low power consumption mode.
- Other reasons cause the battery pack to fail to enter low power consumption normally.

▶ 4.4 Application of Nearing the Ocean

The atmospheric corrosion environment is defined and classified according to the natural environment state, and the A/B environment is defined as follows:

- ullet A: environment refers to the ocean or the land near the pollution source, or the environment with simple shelter (such as awning). "Near the ocean" refers to the area $0.5 \sim 3.7 \, \mathrm{km}$ away from the ocean; "Near the pollution source" refers to the area within the following radius: $3.7 \, \mathrm{km}$ from the saltwater lake, $3 \, \mathrm{km}$ from heavy pollution sources such as smelters, coal mines, and thermal power plants, chemical industry, rubber, electroplating, etc. $2 \, \mathrm{km}$ from medium pollution sources such as chemical industry, rubber and electroplating, etc. And $1 \, \mathrm{km}$ from light pollution sources such as food, leather and heating boilers, etc.
- B: environment. Refers to the environment on land or outside with simple shelter (such as awning) within 500m from the coast, or the environment on the sea.

NOT	E

The battery pack can be used under other environmental conditions and cannot be used alone under A/B environment. If it is to be used in the A/B environment, it needs to be equipped with a high-protection air-conditioning cabinet, which is recommended to be IP55 or higher.



▶ 5.1 Panel Introduction

▶ 5.1.1 Panel Function




Figure 5-1 Front Panel

The interface definition as below table:

Table 5-1 Operation Panel Interface Definition

No.	Name	Description	Remark
1	Battery Output	Power terminal	-
2	LCD	To display status of battery	
3	SOC	State of charge	Details shows in table 5-2
4	ALM	Alarm light	Details shows in table 5-4
5	RUN	Run status of battery	Details shows in table 5-3
6	RESET	Reset switch	-
7	ADD	Dip switch	Address range 0~15
8	RJ-11	RJ-11 interface for firmware update	Used for debugging
9	RJ-45/CAN	2*RJ-45 interface for RS485/ CAN communication	Details shows in table 5-7
10	Dry Contact	NC. / NO. dry contact	Dry contact definition shows in table 5-8
11	МСВ	Power switch	-
12	GND	Module ground connection	-

7



> 5.1.2 Indicator Description

There are 6 Indicators on the operation panel, divided into three categories: 4 green SOC Indicators, 1 red alarm Indicator and 1 green run indicator.

The power indicator is used to identify the current capacity status of the battery. The number of flashing indicators corresponds to different remaining capacity. The specific meaning is shown in the following table.

Table 5-2 SOC Indicator Definition

Number of Indicator	Remaining Capacity Range
1 indicator on	0% < SOC≤25%
2 indicators on	25% < SOC≤50%
3 indicators on	50% < SOC≤75%
4 indicators on	75% < SOC≤100%

Table 5-3 RUN Indicator Definition

Flash Mode	ON OFF		Module Status
Flash 1	0.25 s 3.75 s		Idle
Flash 2	0.5 s	0.5 s	Charge
Flash 3	0.25 s 0.25 s		Stant up failed
Keep On		Discharge	
Keep Off	-	Sleep/Fault	



Table 5-4 Alarm Indicator Definition

Indication Status	ON	OFF	Module Status
Flash 2	0.5 s	0.5 s	Alarm when the Min. cell voltage is < 1.5V Low-temperature protection
Keep On	-		Fault (Charge/Discharge MOS、NTC、 BQ940、ADC Fault)
Keep Off	-		Standby/Sleep

The corresponding relationship between battery operation status and indicator operation status is shown in the following table.

Table 5-5 Battery Status and Indicator Operation Mode


Battery status	Normal/ Abnormal	RUN	ALM	SOC Indicators			Description	
-	-	Green	Red	Green	Green	Green	Green	-
Power off/ Sleep	-	OFF	OFF	OFF	OFF	OFF	OFF	-
Standby	Normal	Flash 1	OFF	According to SOC		Flash mode shown in Table 2		
Charge	Normal	Flash 2	OFF	According to SOC		-		
Discharge	Normal	ON	OFF	According to SOC		-		
Alarm	Abnormal	According to the state of charge and discharge	Flash 2	According to SOC		Recoverable		
Error	Abnormal	OFF	ON	OFF		-		

5 Product Introduction



▶ 5.1.3 DIP Address

To communicate with the battery, you need to assign an address to the battery BMS through the DIP switch.



The relationship between DIP address and BMS address as below:

Table 5-6 Correspondence between BMS and DIP Switch

DIP 1	DIP 2	DIP 3	DIP 4	BMS Address	BMS Address
OFF	OFF	OFF	OFF	0	0N 1 2 3 4 5 6 OFF
ON	OFF	OFF	OFF	1	0N 0N 1 2 3 4 5 6 0FF
OFF	ON	OFF	OFF	2	1 2 3 4 5 6 OFF
ON	ON	OFF	OFF	3	1 2 3 4 5 6 OFF
OFF	OFF	ON	OFF	4	1 2 3 4 5 6 OFF
ON	OFF	ON	OFF	5	0N 1 2 3 4 5 6 OFF
OFF	ON	ON	OFF	6	1 2 3 4 5 6 OFF
ON	ON	ON	OFF	7	0N 0N 0FF
OFF	OFF	OFF	ON	8	0N 1 2 3 4 5 6 0FF
ON	OFF	OFF	ON	9	0N 1 2 3 4 5 6 OFF
OFF	ON	OFF	ON	10	0N 0N 0FF
ON	ON	OFF	ON	11	0N 0N 0FF
OFF	OFF	ON	ON	12	0N 0N 0FF
ON	OFF	ON	ON	13	0N 0N 1 2 3 4 5 6 0FF
OFF	ON	ON	ON	14	0N 0N 1 2 3 4 5 6 0FF
ON	ON	ON	ON	15	0N 0N 0N 0N 0N 0FF

5 Product Introduction



NOTE

- ullet CAN communication setting: set the master battery's DIP address to '0'. and for the remaining battery's DIP addresses need to increase sequentially.
 - RS 485 communication setting: set the batteries' DIP addresses from 1-15.

▶ 5.1.4 Communication Port Definition

RJ 45 definition as below:

Table 5-7 RJ 45 Definition

	Pin	Description
	4	RS485_A
12345678	5	CAN_L
[] []	6	CAN_H
7	7	RS485_B
	8	GND
	1/2/3	NC

> 5.1.5 Dry Contact Alarm Definition

The module uses the default NC. dry contact to provide alarm signals. The alarm definition of the dry contact is defined as follows.

Table 5-8 Dry Contact Alarm Definition

Dry Contact No.	Alarm Definition
Dry Contact 1	Cell voltage differnce alarm; Low cell voltage alarm.
Dry Contact 2	940 module fault; NTC disconnection; Charging and discharging MOS fault;



▶ 6.1 Tools Preparation



Use insulated tools to avoid electric shock. If you use tools without insulation protection, you need to wrap the exposed metal parts with insulation tape for insulation treatment.

The following table describes the tools and meters that may be used before installation.

Table 6-1 Installation

Manual forklift	Electric forklift	Electric screw driver	Adjustable wrench
Phillips screwdriver	Slotted screwdriver	Torque wrench	Claw Hammer
		£	
Socket wrench	Multimeter	Protective gloves	Helmet
		whin	
Insulated shoes	Anti-static gloves	Goggles	Insulating tape
Edding.			10



▶ 6.2 Unpacking and Inspection

- Study this manual carefully before any installation of the batteries.
- The batteries must only be installed and operated by trained personnel.
- Check the quantity of battery and accessories with delivery list.
- Check the appearance whether there is damaged or leakage, if any damage is detected, please do not proceed to the next installation.

▶ 6.3 Preparing for Installation

- Make sure to disconnect and isolate the battery from any electrical source, and then turn on the MCB (switch). Verify that the red ALM LED does not stay on for more than 30 seconds.
 - Turn off the switch and continue with the installation.

▶ 6.4 Installation

1 Make sure the battery is in off status. As shown in Figure 6-1.




Figure 6-1 Make Sure the Battery is in Off Status



2 Put the battery into cabinet or rack. As shown in Figure 6-2.




Figure 6-2 Fix the Battery on the Cabinet or Rack




Figure 6-3 Right Way to Place Battery



NOTE

- The VT48200B battery can applied to install in 19-inch rack / existing cabinets.
- The VT48200B battery preferred to be installed in flat position as Fig 6-3 shown.
- The battery must be fixed tightly with 4pcs M6*25 crown screws.
- The grounding screw is M5*12.
- In case of several battery parallel connection, it is advisable to leave a space of at least 10mm between them.

▶ 6.5 Cable Connection

- Pay attention to the polarity of the battery pack.
- Connect the negative power cables of all battery packs first, and then connect the positive power cables of the battery packs.

1 Connect Ground Cable

Take out the GND cable and connect one end to the ground point of the battery pack and other end to the ground point of the cabinet.




Figure 6-4 Connect Ground Cable



2 Connect Power cable

Use the negative power cable to connect the negative bus bar with the battery negative ('-') terminal, and use the positive power cable to connect the positive bus bar with the battery positive ('+') terminal.




Figure 6-5 Connect the Battery Pack Power Cable

3 Connect Communication Cable

A. Use the communication cable to connect the battery packs in series through the RS485 communication port, and connect the battery packs at the end to the user's RS485 communication port through the RS485 communication port.

B. Assign addresses to battery packs. Assign addresses to battery packs by dialing the dialing keys of the dialing switch. Please refer to 5.2.3 about the correspondence between DIP switch and battery pack address.




Figure 6-6 Connect RS485 Communication Cable



4 120Ω Resistor Connection

To ensure stable CAN communication with the inverter when batteries are used in parallel, please take out a 120Ω resistor from the 'Battery Kit' and insert it into the RJ45 port of the battery that communicates farthest with the inverter.




Figure 6-7 Connect the 120Ω Resistor

5 Set BAT Address

Assign addresses to battery packs by dialing the dialing keys of the dialing switch.

DIP address please refer to 'Table 5-6 Correspondence between BMS and DIP Switch'.

- A. When the battery and the inverter/PCS use the CAN communication mode, the battery connected to the inverter/PCS is set to 0, and the other packs are set to 1/2/3 in sequence.
- B. When the battery and the inverter/PCS use the RS485 communication mode, the battery connected to the inverter/PCS is set to 1, and the other packs are set to 2/3/4 in sequence.



ATTENTION

- Wear safety protection equipment to prevent electric shock from causing electric shock injuries.
 - Use insulated tools to avoid electric shock.
 - Communication cables and power cables must be laid separately.
- Before connecting cables, make sure that the bus-bars at the user end are in disconnected state.
 - Pay attention to the polarity of the battery pack.

> 7.1 Power-on Operation

> 7.1.1 Pre-check Preparing Power-on Operation

After completing the installation of the battery, users need to perform a pre-power check to ensure that the device installation and cable connection are correct.

- Check whether the cables are connected correctly, and the connectors are fastened.
- Check whether the battery pack's power cable terminal is snapped into place and covered with an insulating cover.
 - Check whether the long cables are bundled.
 - Check whether the communication cable and the power cable are separated.
 - Check whether the cabinet, battery pack are grounded.




Figure 7-1 Check the Battery Voltage



> 7.1.2 Power On

- 1 Power on the charger/inverter at the user terminal.
- 2 Set the battery MCB/Switch to ON (if available).
- 3 Observe Run/Alarm indicator and judge the battery operating status. If the RUN indicator of the battery is on and the ALARM indicator is off, indicating that the battery is working normally.
- 4 Please configure the actual number of batteries in parallel connection through the UIWare. As follows.

NOTE

• This section is for professionals only and requires specific tools and software. Currently only open to growcol accredited engineers.



> 7.1.3 UIWare Configuration




Figure 7-2 Configuration Page

- 1 Connect the UIWare by computer successfully.
- 2 Click the 'HOMESTORE' page.
- 3 Select the actual number of batteries in parallel connection on the 'SYSTEM PACK SUM'
 - 4 Click the 'Write' button to finish the setting.
 - 5 Restart the battery.

NOTE

• Please refer to the "UIWare User Manual" for more UIWare operations.



NOTE

• Please refer to the section 7.2 to get information of battery system parameter setting, refer to the section 5.2.2 to get information of indicator description.

⚠ WARNING

- Follow the power-on procedure to power on the battery pack strictly.
- Make sure to turn on the charger/inverter firstly, before turning on the battery MCB/Switch.
 - Must not change the parameters casually in the site.
- After VT48200B series batteries goes into the sleeping status, please turn on the Battery MCB/Switch against or press the reset button.

> 7.1.4 Check by UI software

Connect the PC UI software to confirm the system running information been displayed normally. If the displays normally, then we can know the battery is well and the parameter settings are right.




Figure 7-3 Page of UI Software





- Details refer to the "Operation Manual of the UI Software" .
- Please recharge the battery before put into use according to this manual.

> 7.2 Power System Parameter Setting

Table 7-1 Parameter Setting

Na	No. Parameters		Standard Value	
NO.	Parameters	Units	15S	16S
1	Equalization charge voltage	V	54.1	56.5
2	Float charge voltage	V	54.0	56.4
3	Standard charge current	А	0.2C	0.2C
4	Charge current limitation	А	20.0	20.0
5	Condition to equalization charge	А	NA	NA
6	Condition to float charge	А	0.05C	0.05C
7	Recovered LLVD voltage	V	50.0	53.3
8	LLVD	V	47.0	50.1
9	BLVD	V	43.2	46.1
10	Temperature compensation for float charge	-mV/°C	NA	NA
11	Temperature compensation for equalization charge	-mV/°C	NA	NA

NOTE

- The content in the table is just our suggestion, and actually need to refer to other related requirements.
 - The setting items of different chargers will be different.

8 Shipment & Maintenance & Storage



8.1 Shipment

It is suitable for the transportation of vehicles, ships and airplanes. During transportation, shading, sun protection and civilized loading and unloading should be performed. The box containing the product is allowed to be transported by any means of transportation. In the process of loading and unloading, the battery should be handled with care to prevent falling, rolling, and heavy pressure. Avoid direct rain and snow and mechanical impact during transportation.

And here is the suggestion for the initial SOC before shipment by different transportation:

- Airplane:30%
- Sea:50%
- Vehicle:50%

NOTE

• Whether the loading SOC status of the battery is allowed, you need to consult the relevant government transportation department.

8.2 Maintenance

8.2.1 Battery Maintenance Considerations

When maintaining the battery, it is required to use insulated tools or wrap the tools in insulation.

- DO NOT place any debris on the top of the battery.
- DO NOT use any organic solvents to clean the battery.
- DO NOT smoke or use naked flames near the battery.
- After the battery is discharged, the battery should be charged in time to avoid affecting the battery life.
- \bullet When not using the battery for a long time, please charge the battery to 40%~50% charged state. Long-term storage with low battery may damage the battery.
 - All maintenance work must be carried out by professionals.



▶ 8.2.2 Routine Maintenance

The staff should perform visual inspection on VT48 series battery according to the inspection plan, please refer to the following table for maintenance.

Table 8-1 Routine Maintenance (Every three-month)

Items	Standard	Dealing
Battery Appearance	 The surface is neat and clean without stains. The terminals are in good condition. The battery pack shell is intact, and there is no bumps, breaks, or leakage. The appearance of the battery pack does not leak. No deformation or swelling of the shell. 	 If the surface is dirty, clea n the appearance of the battery pack with a cotton cloth. The battery pack terminal is damaged, replace the cable. If the appearance is damaged, leaking or deformed, take a photo and replace the defective battery pack. Please contact Vtac in time for other abnormal situations.
Alarm	No Alarm.	• Find the solution as per alarm information.

NOTE

• Suggested routine maintenance for every three-month.



Table 8-2 Routine Maintenance (Every six-month)

Items	Standard	Action
(Suggested) Complete Cycle	Have a complete charge & discharge cycleunder the equipment no lack of power.	 Check whether happens alarm action, and please check with the alarm list. Please contact with Vtac if the alarm still exists.
Cables	 There is no aging of the connecting wire and no cracking of the insulation layer. The bolts at the cable connection are not loose. 	Replace the faulty connection.Fastening bolts.

▶ 8.3 Battery Storage

- The recommended storage temperature is 15°C~35°C.
- Battery performance degradation after long-term storage, please shorten shelf time as possible as you can.
- Recharge charge before using to recover capacity loss of self-discharge during storage and transport.
- Storage battery should be at 40%-50%SOC when the battery is not used for a long time.
 - Storage battery over 40°C or under 0°C will reduce battery life.
 - Storage battery in dry and low temperature, well ventilated place.

If the battery is not used for a long time, the battery must be charged at regular intervals. The charging requirements are as follows:

Table 8-3 Battery Charge Requirement in Storage Status

Storage Temp.	Charge Period	Charge Process
20°C~30°C	Each 6 months	1.Charge by 0.2C to 100% SOC
0°C~20°C or 30°C~40°C	Each 3 months	2.Discharge by 0.2C to 0% SOC
		3.Charge by 0.2C to 40%~50% SOC



Please refer to the table below to deal with common faults:

Table 9-1 FAQ

Phenomenon	Possible Cause	Solution
	The power cable of the battery pack is not properly connected.	Reconnect the power cable of the battery pack
The indicator	The power switch is off.	Turn on the power switch.
does not flash	The BMS is in a sleep state.	Charge the battery pack
	BMS is damaged.	Replace BMS.
	The terminal of the battery pack is damaged.	Replace the battery pack wiring terminals.
Unable to		Reconnect the communication line between the BMS
discharge	BMS communication failure.	and the battery pack. If the communication cable is
		damaged, replace the communication cable.
	The power switch is off.	Turn on the power switch.
	The charger is malfunctioning.	Replace the charger.
	The terminal of the battery pack is damaged.	Replace the battery pack wiring terminals.
Unable to		Reconnect the communication line between the BMS
charge	BMS communication failure.	and the battery pack. If the communication cable is
		damaged, replace the communication cable.
	The power switch is off.	Turn on the power switch.
	The power switch is off.	Turn on the power switch.
Communication	The BMS is in a sleep status.	Charge the battery pack
fail	The communication cable is damage.	Replace the network cable.
Inaccurate	The voltage sampling line is damaged.	Replace the voltage sampling cable.
voltage display	BMS is damaged.	Replace BMS.
	The battery pack has not been maintained for a long time.	Use an equalizer to maintain the battery pack.
Low capacity	The single battery is damaged.	Replace the damaged single battery.
	Inaccurate voltage sampling.	Replace the electrical sampling line or replace the BMS.
	The battery pack has not been maintained for a long time.	Use an equalizer to maintain the battery pack.
Low cell voltage	The single battery is damaged.	Replace the damaged single battery.
	Inaccurate voltage sampling.	Replace the electrical sampling line or replace the BMS.



Except for the following and the conditions specified in the contract, you can go to Vtac and authorized dealers for reasonable warranty and maintenance.

- 1 Failure of equipment caused by unauthorized disassembly and maintenance operations without the authorization of Vtac and authorized dealers is not within the scope of the warranty.
- 2 Equipment damage caused by negligence during storage and transportation is not covered by the warranty.
- 3 The damage to the equipment caused by continuous overload work outside the electrical parameters of the equipment is not covered by the warranty.
- 4 Unauthorized testing of the equipment without the authorization of Vtac and authorized dealers will not be covered by the warranty.
- 5 Non-equipment problems, adverse consequences caused by operation and matching problems are not covered by the warranty.
- 6 Equipment damage caused by natural forces, force majeure, and uncontrollable factors, such as earthquakes, typhoons, tornadoes, volcanic eruptions, floods, lightning, heavy snow, and wars, is not covered by the warranty.
- 7 If the product serial number is changed, blurred, or torn, it is not covered by the warranty.

TECHNICAL DATA

Model No	VT-48200B
SKU Code	11523
Net Weight	81kg
Size(MM)	445*244*500mm
Nominal Capacity	200Ah@0.2C, 25C
Nominal Voltage	48.0V
Nominal Energy	9.60kWh@0.2C, 25C
Charge Voltage	54.0V
Standard Charge Current	20A@25C
Max Continuous Charge Current	100A@25C
Standard Discharge Current	20A@25C
Max Continuous Discharge Current	100A@25C
Discharge Cut-off Voltage	40.5V
Operating Temperature	Charge:0~+60C -Discharge :- 20~+60C
Allowed Humidity Range	≤95% RH
IP	IP 20

11 Abbreviations



BMS	Battery Management System
D	Depth
Н	Height
W	Width
LCD	Liquid Crystal Display
LFP	LiFePO4
MOSFET	Metal-Oxide-Semiconductor Field-Effect
	Transistor
NTC	Negative Temperature Coefficient
PC	Personal Computer
PCB	Printed Circuit Board
PCS	Power Conversion System
RTU	Remote Terminal Unit
SOC	State of Charge

IMPORTANT NOTES

- This product contains battery type "Secondary" (rechargeable).
- Electrical and electronic equipment that has become waste is known as old equipment/device. Old devices must not be disposed of with other household waste.
- Owners of old devices at the end of its service life must return the device by taking them to the collection points set up by public waste disposal authorities or distributors. This return does not entail any costs for you.
- Owners of old devices have an obligation to remove accessible batteries / rechargeable batteries as well as non-destructively removable lamps from the old device prior to return. This does not apply if old devices are being prepared for reuse with the participation of a public law firm.
- Battery removal warning: The battery contained in this product must be removed only
 by professional personnel only. The battery must never be removed by the end user, if
 not removed correctly it could damage the battery which could cause fire.
- Batteries removed from an old electronic device should be disposed of separately. This
 return of battery does not entail any costs for you and the user is obliged to return the
 battery.
- Please make sure that this product is not powered on when removing the battery. Fire hazard! Avoid short-circuiting the contacts of a detached battery. Do not incinerate the battery. Please handle the battery with Caution!
- If electrical appliances or batteries are disposed of in landfills or dumps, hazardous substances can leak into the groundwater and get into the food chain, damaging your health and well-being.



- The symbol of "Crossed rubbish bins "indicates that this product should not be disposed of with other household wastes and must be collected separately from unsorted municipal waste at the end of its service life.
- Please use the link below to view the online directory of the collection and return points:https://www.ear-system.de/ear-verzeichnis/sammel-und-ruecknahmestellen



Meaningful Innovation.

VTAC EUROPE LTD Bulgaria, Plovdiv 4000, bul.L.Karavelow 9B